

# WATER QUALITY REPORT

No. L11C0073-001 1/1 -1

**Client :** Tokyo Port Terminal Corporation,  
Port Service Office

**Sample Received :** 2011/12/01

**Report Date :** 2011/12/07

**Purpose of Test :** To determine if sample meets  
with Government Standards

**Sample Type :** City Water supply

**Date/Time :** 2011/12/01

**Location :** 1st floor  
A feed cock for water supply  
ships

Certified Inspector of Drinking Water Quality for Buildings:  
Registered No.23  
Licensed Measurer Verifying and Registering Measurements:  
Concentration No.557

**NIPPON BUNSEKI co.,ltd.**

Head Office and Analysis Center  
2-26-14,Azusawa,Itabashi-ku,Tokyo,174-0051,Japan

TEL : 03-5914-4431 FAX : 03-5914-4432

**Officer in charge** Koichi Toyama



**Result :** Cleared Government Standards

Item	Result of analysis	Govt.Standards
General Bacteria	0	100 colonies/1ml or less
Escherichia coliform	Not detected	Non-detectable amount
Nitrate and nitrite nitrogen	2.6	10mg/l or less
Ionic chlorine	17.4	200mg/l or less
Organic substances (Total Organic Carbon (TOC))	0.6	3mg/l or less
pH	7.3	Between 5.8 and 8.6
Taste	normal	Tasteless
Odor	normal	Odorless
Chromaticity	less than detectable limit (1)	5 degrees or below
Turbidity	less than detectable limit (0.5)	2 degrees or below

-Here follows blank space-

**Method** Health and Welfare Ministry regulation No.101 May. 2003

[TREFARMEDPULP]

