

WATER QUALITY REPORT

No. L11C0072-001 1/1 -1

Client : Harumi Passenger Ship Terminal

Sample Received : 2011/12/01

Report Date : 2011/12/07

Purpose of Test : To determine if sample meets with Government Standards

Sample Type : City Water supply

Date/Time : 2010/12/01

Location : A test valve for pump suction pipes

Certified Inspector of Drinking Water Quality for Buildings:
Registered No.23
Licensed Measurer Verifying and Registering Measurements:
Concentration No.557

NIPPON BUNSEKI co.,ltd.

Head Office and Analysis Center

2-26-14,Azusawa,Itabashi-ku,Tokyo,174-0051,Japan

TEL : 03-5914-4431 FAX : 03-5914-4432

Officer in charge Koichi Toyama



Result : Cleared Government Standards

Item	Result of analysis	Govt.Standards
General Bacteria	0	100 colonies/1ml or less
Escherichia coliform	Not detected	Non-detectable amount
Nitrate and nitrite nitrogen	2.4	10mg/l or less
Ionic chlorine	17.1	200mg/l or less
Organic substances (Total Organic Carbon (TOC))	0.6	3mg/l or less
pH	7.4	Between 5.8 and 8.6
Taste	normal	Tasteless
Odor	normal	Odorless
Chromaticity	less than detectable limit (1)	5 degrees or below
Turbidity	less than detectable limit (0.5)	2 degrees or below
-Here follows blank space-		

Method Health and Welfare Ministry regulation No.101 May. 2003

[TREEFARMEDPULP]

