Certificate of Water Analysis

No.A1705944- 002
Date of Issue: February 21, 2018

Esc Yokohama
Environmental Analysis Service Company,Ltd.
TEL 045(785)2914

Client: Water supply ship "SUIREN"

Sample Collection Place : 9-1, Kojimacho, Kawasaki-ku, Kawasaki-shi, Kanagawa
Date of Sample Collection : February 14, 2018 (15:00)
Date of Sample Received : February 16, 2018

Parameter	Unit	Test Results	Water Quality Standards
Nitrate-N and Nitrite-N	mg/L	1.1	≦10
Nitrite-N	mg/L	＜0.004	≦0.04
Chloride Ion	mg/L	8	≦200
Total Organic Carbon	mg/L	0.4	≦3
Bacteria	CFU/mL	0	≦100
E.Coli	—	Not Detected	Not Detected
pH	—	7.5(25.1℃)	5.8～8.6
Odor	—	Notparticular	Not Detected
Taste	—	Notparticular	Not Detected
Color	CU	＜0.5	≦5
Turbidity	NTU	＜0.2	≦2

Suitability of Water Quality	Y (○)	Analyst
	N ( ) *	

Water Quality Standards depend on Ministry of Health,Labour and Welfare law 101.
CFU=Colony Forming Unit
CU=Color Unit
NTU=Nephelometric Turbidity Unit