Certificate of Water Analysis

№E0165165-002

Date of Issue: January 20,2017

Client: Water supply ship "SUIREN"

Esc Yokohama
Environmental Analysis Service Company,Ltd.

Sample Collection Place: 9-1, Kojimacho, Kawasaki-ku, Kawasaki-shi, Kanagawa TEL 045(785)2914

Date of Sample Collection: January 16,2017 (14:00)
Date of Sample Received: January 17,2017

Parameter	Unit	Test Results	Water Quality Standards
Nitrate-N and Nitrite-N	mg／L	1.1	≦10
Nitrite-N	mg／L	＜0.004	≦0.04
Chloride Ion	mg／L	7	≦200
Total Organic Carbon	mg／L	0.5	≦3
Bacteria	CFU／ml	21	≦100
E.Coli	—	Not Detected	Not Detected
pH	—	7.7 (24.7℃)	5.8～8.6
Odor	—	Notparticular	Not Detected
Taste	—	Notparticular	Not Detected
Color	CU	＜0.5	≦5
Turbidity	NTU	＜0.2	≦2
Suitability of Water Quality	Y (O)	Analyst	
	N ( ) *		

Water Quality Standards depend on Ministry of Health,Labour and Welfare law 101.
CU=color units
NTU=nephelometric turbidity units