

Certificate of Water Analysis

No.A1905771- 002

Date of Issue: January 30, 2020

Client: Water supply ship "SUIREN"

Esc Yokohama
Environmental Analysis Service Company, Ltd.

TEL 045(785)2914



Sample Collection Place : 9-1, Kojimacho, Kawasaki-ku, Kawasaki-shi, Kanagawa
Date of Sample Collection : January 21, 2020 (10:00)
Date of Sample Received : January 23, 2020

Parameter	Unit	Test Results	Water Quality Standards
Nitrate-N and Nitrite-N	mg/L	1.1	≤ 10
Nitrite-N	mg/L	< 0.004	≤ 0.04
Chloride Ion	mg/L	6	≤ 200
Total Organic Carbon	mg/L	< 0.3	≤ 3
Bacteria	CFU/mL	0	≤ 100
E.Coli	—	Not Detected	Not Detected
pH	—	7.5(26.4°C)	5.8~8.6
Odor	—	Notparticular	Not Detected
Taste	—	Notparticular	Not Detected
Color	CU	< 0.5	≤ 5
Turbidity	NTU	< 0.2	≤ 2
Suitability of Water Quality	Y (○) N () *		Analyst



Water Quality Standards depend on Ministry of Health, Labour and Welfare law 101.
CFU=Colony Forming Unit
CU=Color Unit
NTU=Nephelometric Turbidity Unit