

## Examination transcript of water quality

To : Tokyo Port Terminal Corporation, Harumi Wharf ship water supply institution

Japan Recreation and Miscellaneous Goods Safety Laboratory  
 Registration 56-SUI No. 4, Tokyo  
 4-22-7, Honjo, Sumida-ku, Tokyo 130-0004  
 TEL 81-3-3829-2512 FAX 81-3-3829-3923



We hereby certify that the test results of the sample commissioned to us on February 13, 2020, are as shown below.

Description of sample	Tap water	Date of sampling	February 13, 2020	Time of sampling	10:10 a.m.
Place of sampling	5-6 Harumi, Chuo-ku, Tokyo Harumi Wharf ship water supply facilities, No11, water tap (pier)				
Purpose of sampling	Conformity examination to the water quality standards of the Waterworks Act				
Name of sampler	Tomonori Kobayashi				

Examination item	Result	Standard value	Examination item	Result	Limit
Common bacteria (no./ml)	ND	≤100			
E. coli (in 100 ml)	ND	ND			
Nitrite-nitrogen (mg/l)	<0.004	≤0.04			
Nitrate-nitrogen and nitrite-nitrogen (mg/l)	2.2	≤10			
Chloride ion (mg/l)	26	≤200			
Organic substances (total organic carbon - TOC) (mg/l)	0.7	≤3			
pH value (pH)	7.2 (20 °C)	5.8 ~8.6			
Odour	No abnormality	No abnormality			
Taste	No abnormality	No abnormality			
Colour degree (degree)	4	≤5			
Turbidity (degree)	<1	≤2			
----- Blank below -----					

Examination methods	Examination methods established by minister of health, labour and welfare, Notification No. 261, 2003, MHLW
Person responsible for examination	Shinobu Katagiri
Judgment	The above examination results meet the water quality standards.
Remarks	February 13 17:00 examination start.