

WATER QUALITY REPORT

No. L19C1615-001 1/1 -1

Consigner : Tokyo Port Terminal Corporation
Name of facility : Tokyo Port Terminal Corporation,
Port Service Office

Sample Received : 2019/12/09

Report Date : 2019/12/12

Purpose of Test : To determine if sample meets with Government Standards

Sample Type : City Water supply

Date/Time : 2019/12/09 12:00

Location : First floor a feed cock for water supply ships
1-1-3, Yashio, Shinagawa-ku, Tokyo

No. 240 Registered Water Quality Inspection Agency on Article 20 of Water Law's
No. 150 registered Private Water Supply Inspection Agency on Article 34 of Water Law
Certified Inspector of Drinking Water Quality for Buildings:
Registered No.23
Licensed Measurer Verifying and Registering Measurements:
Concentration No.557

NIPPON BUNSEKI co., Ltd.

Head Office and Analysis Center
2-26-14, Azusawa, Itabashi-ku, Tokyo, 174-0051, Japan
TEL : 03-5914-4431 FAX : 03-5914-4432

Officer in charge Tatsuya Ikeda



Result : Cleared Government Standards

Item	Result of analysis	Govt. Standards
Standard plate count	0	100 in 1mL or less
Coliform	Not detected	Not to be detected
Nitrite nitrogen	less than detectable limit (0.004)	0.04mg/L or less
Nitrate nitrogen and nitrite nitrogen	2.1	10mg/L or less
Chloride ion	19.0	200mg/L or less
Organic substances (Total Organic Carbon (TOC))	0.5	3mg/L or less
pH value	7.2	Between 5.8 and 8.6
Taste	normal	Not abnormal
Odor	normal	Not abnormal
Color	less than detectable limit (1)	5 degrees or less
Turbidity	less than detectable limit (0.5)	2 degrees or less

-Here follows blank space-

Method Notification of the Ministry of Health No.261 July 22. 2003

Pulp of plantation wood / 95% whiteness

There is a mark (hole) of "Nichi Bun" on all report issued by the this company.

