Sample ID: H2300818-002
Report Date: 2023/8/18

WATER QUALITY REPORT

Certified Inspector of Drinking Water Quality for Buildings:
Registered No.82
Lioensed Measurer Verifying and Registering Measurements:
Conoentration No.1350
NIHON JOUKA Co.,Ltd.
5-26-30,Shiba,Minato-ku,Tokyo,108-0014,Japan
TEL:03-3798-0091 FAX:03-3798-0451
Officer in charge Ayami Takano

Sample Type : City Water supply
Purpose of Test : To determine if sample meets with Government Standards
Consigner : Tokyo International Cruise Terminal
Sampling Location : Tokyo International Cruise Terminal,terminal quay faucet1
Location : 2-8,Aomi,Koto-ku,Tokyo
Date/Time : 2023/8/9 10:08

Method Notification of the Ministry of Health No.261 July 22.2003

Result	Cleared Government Standards	
Item	Result of analysis	Govt.Standards
Standard plate count	Not detected	100 in 1mL or less
Coliform	Not detected	Not to be detected
Nitrite nitrogen	1.0	0.04mg/L or less
Nitrate nitrogen and nitrite nitrogen	less than 0.004	10mg/L or less
Chloride ion	22	200mg/L or less
Organics substances <Total Organic Carbon(toc)>	1.0	3mg/L or less
pH value	7.6	Between 5.8 and 8.6
Taste	normal	Not abnormal
Odor	normal	Not abnormal
Color	less than 0.5	5 degrees or less
Turbidity	less than 0.2	2 degrees or less
	Here follows blank space	