Sample ID:

K2301206-002

Report Date:

2023/12/4

WATER QUALITY REPORT

Certified Inspector of Drinking Water Quality for Buildings:

Registered No.82

Lioensed Measurer Verifying and Registering Measurements:

Concentration No.1350

NIHON JOUKA Co.,Ltd. 5-26-30,Shiba,Minato-ku,Tokyo,108-0014,Japan

TEL:03-3798-0091 FAX:03-3798-0451

Officer in charge

Ayami Takano

Sample Type: City Water supply

Purpose of Test: To determine if sample meets with Government Standards

Consigner: Tokyo International Cruise Terminal

Sampling Location: Tokyo International Cruise Terminal, terminal quay faucet No.9

Location: Aomi 2-chome, Koto-ku, Tokyo 135-0064, Japan

Date/Time: 2023/11/28

Notification of the Ministry of Health No.261 July 22.2003 Method

Result	Cleared Government Standards		
Item		Result of analysis	Govt.Standards
Standard plate count		Not detected	100 in 1mL or less
Coliform		Not detected	Not to be detected
Nitrite nitrogen		2.3	0.04mg/L or less
Nitrate nitrogen and nitrite nitrogen		less than 0.004	10mg/L or less
Chloride ion		22	200mg/L or less
Organics substances <total carbon(toc)="" organic=""></total>		0.7	3mg/L or less
pH value		7.5	Between 5.8 and 8.6
Taste		normal	Not abnormal
Odor		normal	Not abnormal
Color		less than 0.5	5 degrees or less
Turbidity		less than 0.2	2 degrees or less
		Here follows blank space	