

WATER QUALITY REPORT

No. L23C0416-001 1/1 -1

Consigner : Tokyo Port Terminal Corporation
Name of facility : Tokyo Port Terminal Corporation,
Harumi Wharf ship water supply
institution

Sample Received : 2023/12/04

Report Date : 2023/12/08

Purpose of Test : To determine if sample meets
with Government Standards

Sample Type : City Water supply

Date/Time : 2023/12/04 11:50

Location : A test valve for pump suction
pipes
5-6, Harumi, Chuo-ku, Tokyo

No. 240 Registered Water Quality Inspection Agency on Article 20 of Water Law's
No. 150 registered Private Water Supply Inspection Agency on Article 34 of Water Law
Certified Inspector of Drinking Water Quality for Buildings:
Registered No.23
Licensed Measurer Verifying and Registering Measurements:
Concentration No.557

NIPPON BUNSEKI co.,ltd.

Head Office and Analysis Center
2-26-14, Azusawa, Itabashi-ku, Tokyo, 174-0051, Japan
TEL : 03-5914-4431 FAX : 03-5914-4432

Officer in charge Tatsuya Ikeda

Result : Cleared Government Standards

| Item | Result of analysis | Govt.Standards |
|--|------------------------------------|---------------------|
| Standard plate count | 0 | 100 in 1mL or less |
| Coliform | Not detected | Not to be detected |
| Nitrite nitrogen | less than detectable limit (0.004) | 0.04mg/L or less |
| Nitrate nitrogen and nitrite nitrogen | 2.0 | 10mg/L or less |
| Chloride ion | 21.3 | 200mg/L or less |
| Organic substances (Total Organic Carbon (TOC)) | 0.7 | 3mg/L or less |
| pH value | 7.5 | Between 5.8 and 8.6 |
| Taste | normal | Not abnormal |
| Odor | normal | Not abnormal |
| Color | less than detectable limit (1) | 5 degrees or less |
| Turbidity | less than detectable limit (0.5) | 2 degrees or less |

-Here follows blank space-

Method Notification of the Ministry of Health No.261 July 22, 2003

Pulp of plantation wood / 95% whiteness

There is a mark (hole) of "Nichi Bun" on all report issued by the this company.